STOVICEK Heating and Cooling - Since 1927 A Division of		
		MERCIAL PRESIDENTIAL
BOILER CHECKLIST		
Ye	<u>s N/</u>	<u>A</u>
		Check Thermostat Operations
_		(Replace common sized batteries)
		(Hot Water / Steam / Condensing /
		High Pressure Steam)
		Check and Clean Burners
		Record PSI
		Check(PRV)water pressure regulator Check if regulator bypass is present(Y / N)
		Check condition of gauge glass
		(CLEAN / FAIR / POOR)
		Check operation of draft damper
		Check operation of gas valve
		Check operation of ignition system
		Check operation of circulating pump(s)
		Check all zone control(s)
		Evaluate condition of piping
		(CLEAN / FAIR / POOR)
		Check drains
		Check operation of combustion blower
		Check the low water cut off switch
		Check automatic water feeder Check all limits
		Check Expansion Tank
		Verify relief valve set PSI
		Check Condensate pump and tank
		Perform combustion air test to ensure
		that there is enough ventilation to replace
		combustion air
		Operate boiler through one complete
_	_	cycle and clean boiler cabinet
		Attach sticker/service tag
		Equipment Condition
		(NEW / GOOD / FAIR / POOR) Review Procheck results with customer
		29410 Ambina Drive
		Solon, Ohio 44139 440-349-9989 • Fax: 440-349-9979
		www.kwlang.com